



2 Cameras in
Parking lot (Spectra)

TYPICAL FOR ALL CONDUITS
ROUTED UNDER SLAB

NOTE
FURNITURE SHOWN FOR
REFERENCE ONLY SEE MBI
SYSTEMS, INC DRAWINGS FOR
ACCURATE WORKSTATION LAYOUT

Revised 2 phases 10/6/99!
Leave boxes blank for future!

GENERAL NOTES

- PLEASE REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR COORDINATION WITH OTHER TRADES.

FLAG NOTES

- ▲ PROVIDE FLUSH-MOUNTED FIRE ALARM REMOTE ANNUNCIATOR
- ▲ SEE SHEET 2.1 FOR FLOOR BOX INFORMATION, THIS ROOM.
- ▲ PROVIDE CONNECTION FOR DATA TOWER PRE-ACTION SYSTEM TO MAIN BUILDING FIRE ALARM SYSTEM, INCLUDING WATER FLOW, VALVE POSITION, AND ONE ZONE PER FLOOR.

M
MITHUN
PARTNERS
414 OLIVE WAY
SUITE 500
SEATTLE, WA 98101
(206) 467-0554
FAX (206) 467-0555

SPARLING
ELECTRICAL ENGINEERING,
LIGHTING DESIGN &
TECHNOLOGY CONSULTING
720 OLIVE WAY SUITE 1100
SEATTLE, WA 98101-1853
FAX 206-667-0554
PHONE 206-667-0555

SUN HEALTHCARE SYSTEMS, INC.
CAMPUS: PHASE ONE
ANACORTES, WASHINGTON

DATE: _____
SCALE: _____
5/18/99 CONST. SET
DOUG BORS
BILL VAN VLACK, PE
ED SANTOS



COMM/FA/ACCESS
CONTROL PLAN
FIRST FLOOR

98060
DATE: FEBRUARY 9, 1999
SCALE: 1/8" = 1'-0"

E4.1
CONSTRUCTION SET