



**TERMINAL BOX SCHEDULE (BOXES 221-244)**

BOX NO.	221	222	223	225	227	228	229	230	232	233	234	235	237	238	239	241	242	243	244
TYPE	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
SIZE	3	2	2	2	2	3	2	6	5	4	5	2	3	2	2	6	4	5	2
INLET SIZE	10	6	8	6	8	10	8	16	12	12	14	8	10	6	6	14	12	14	8
MAX. PRIMARY CFM	1100	200	400	300	500	825	400	2200	1500	1300	1550	400	1000	350	200	2000	1250	1600	400
MIN. PRIMARY CFM	350	100	150	100	150	300	150	750	550	450	550	200	350	150	100	700	450	550	150
FAN CFM	1100	200	400	300	500	825	400	2200	1200	1300	1550	400	1000	350	200	2000	1250	1600	400
Htg. COIL KW	10	5	4	4	3	4	3	10	11	6	10	1	8	1	1	14	5	10	3
VOL./PHASE	480/3	480/3	480/3	480/3	480/3	480/3	480/3	480/3	480/3	480/3	480/3	480/3	480/3	480/3	480/3	480/3	480/3	480/3	480/3
STEPS	2	1	2	1	1	2	2	2	2	2	2	2	2	1	1	2	2	2	2
FAN HP	1/4	1/6	1/6	1/6	1/6	1/4	1/6	3/4	1/3	1/3	1/3	1/6	1/4	1/6	1/6	3/4	1/3	1/3	1/6
VOL./PHASE	277/1	277/1	277/1	277/1	277/1	277/1	277/1	277/1	277/1	277/1	277/1	277/1	277/1	277/1	277/1	277/1	277/1	277/1	277/1
REMARKS																			

TYPE 1 - SERIES FAN-POWERED TITUS "DFCL"  
 TYPE 2 - SERIES FAN-POWERED TITUS "DTGS"



SCALE 1/8"=1'-0"

CONSTRUCTION SET  
 5/18/99  
 ENTIRE SHEET

N.B.  
 PARTNER IN CHARGE  
 PROJECT MANAGER  
 R.V.  
 PROJECT ARCHITECT  
 D.A.J.  
 DRAWN  
 P.M.J.  
 CHECKED



SIDER & BYERS  
 ASSOCIATES, INC.  
 ARCHITECTS  
 180 WILKINSON BLVD. 204  
 SEATTLE, WASHINGTON 98101  
 (206) 288-8888 FAX (206) 288-1848

SECOND FLOOR PLAN

98046  
 5/18/99  
 M2198046  
 DWG FILE NAME

CAD FILE: CAD:\98046\M2198046  
 PLOT DATE: FEB 9, 1998 11:30 AM